

# BELZONA REPAIRS MAIN COOLING WATER SYSTEM FLANGE

ID: 1360



## PROBLEM

A new spool had been manufactured to connect the intake pipe to the rest of the cooling water system. During welding, the flange on this spool had become warped and following the subsequent machining was found to be up to 9mm undersized.

## APPLICATION SITUATION

Flange on seawater intake pipe of cooling system for nuclear power station

## APPLICATION METHOD

The application was carried out in accordance with Belzona Know-How System Leaflet VPF-13. After applying the Belzona product, on-site machining was used to achieve correct dimensions.

## BELZONA FACTS

This application follows the successful coating of the pipe internals with Belzona® 1321 in 2006. After 3 years this coating had been found to be in excellent condition, when this problem arose Belzona was the first and obvious choice. Belzona has been used many times to repair damaged flanges. The only alternative available to the client was to prefabricate the spool which represented unacceptable down-time.

## INDUSTRY

Power

## LOCATION

Nuclear Power Station, UK

## APPLICATION DATE

September 2009

## PRODUCTS

Belzona 1111 (Super Metal)

## SUBSTRATE

Steel

## PHOTOS

1. Belzona 1321 coating on puddle pipe
2. Application of the Belzona 1111
3. Machining of the cured Belzona 1111
4. The completed application

For more examples of Belzona Know-How in Action, please visit [khia.belzona.com](http://khia.belzona.com)

Belzona products are manufactured under an ISO 9001 Registered Quality Management System.

[www.belzona.com](http://www.belzona.com)

