

BELZONA 1251 PREVENTS MAJOR PLANT SHUTDOWN

ID: 8281



PROBLEM

The original wall thickness was 9.56(mm) The current thickness is around 3mm in different spots and unable to UT the weld before the neck. This is on live equipment and due to the location of the spool rope access was required.

APPLICATION SITUATION

400NB Spool on the client's Cyclone Feed Line with an operating temperature of 80(°C) running Caustic Slurry. The pipeline in question is critical to the client, if it failed, it would mean the plant would be at half capacity.

APPLICATION METHOD

A DRY wrap of the 9341 reinforcement tape was used to determine how much was required. A thin layer of Belzona 1251 was applied to all prepared areas pushing it well into the surface. We then Wet out a length of Belzona® 9341 with Belzona 1251. The tape coated side down to the repair was wrapped firmly around the pipe until 1251 is forced through to the outer surface. We applied a further layer of Belzona 1251 at approximately 6mm thick to completely seal the surface.

BELZONA FACTS

As a replacement for this spool was not possible due to the plant having an unplanned shutdown, a repair to this spool was critical. If it had ruptured it would have shut down 50% of the site's operation.

INDUSTRY

General Industry

LOCATION

Western Australia

APPLICATION DATE

May 2020

PRODUCTS

Belzona 1251 (HA-metal)

Belzona 9341 Reinforcement Tape

SUBSTRATE

Carbon Steel

PHOTOS

1. Spool location
2. Spool condition prior to repair
3. Repair using 1251 and 9341
4. Repair using 1251 and 9341

For more examples of Belzona Know-How in Action, please visit khia.belzona.com

Belzona products are manufactured under an ISO 9001 Registered Quality Management System.

www.belzona.com

