

PIPE STRENGTHENING WITH BELZONA SUPERWRAP II

ID: 9330



PROBLEM

A 60" carbon steel pipe that had suffered from external corrosion and metal loss over the years. The defective area was about 15 feet. They required a solution that would reinstate the structural integrity of the pipe.

APPLICATION SITUATION

We used ASME PCC2 equations to estimate the number of wraps required to retrofit the pipe to design conditions. The defect was type A (thin wall), corrosion was external, and the pressure was relatively low (25 psi). 2 wraps of Belzona SWII were recommended to structurally reinforce the pipe and effectively stop corrosion on the pipe. This repair system can remain maintenance-free for up to 20 years.

APPLICATION METHOD

First, the pipe was grit blasted and prepared according to SSPC SP10. All the pitting and resurfacing was then done with Belzona 1121(Super XL-Metal) because of its longer overcoating time. The next day, they started applying Belzona SWII. They applied the wrap in 4 feet sections at a time, so every 4 feet they would consolidate the repair with Belzona 9382 and continue with the next section. Though the application was during colder climate, Belzona 1982 was chosen to give more working life and allow the crew to complete the application properly.

BELZONA FACTS

Customer received an ISO/ASME compliant repair system able to stop the corrosion, return the mechanical strength back to the water pipe and designed to provide a 20 year lifetime.

INDUSTRY

Local Authorities & Municipalities

LOCATION

Toronto, Ontario

APPLICATION DATE

November 2020

PRODUCTS

Belzona 1121 (Super XL-Metal)
Belzona 1982 (SuperWrap II)
Belzona SuperWrap II

SUBSTRATE

Carbon steel

PHOTOS

1. Corroded section of the pipe
2. Application of Belzona 1121
3. Wrapping in 4 feet sections
4. Wrap completed and consolidated with Belzona 9382

For more examples of Belzona Know-How in Action, please visit khia.belzona.com

Belzona products are manufactured
under an ISO 9001 Registered
Quality Management System.

www.belzona.com

