

EXTERNAL REPAIR TO WATER TANK

ID: 9905



PROBLEM

A constant leak meant that production water was escaping from a water tank in a large food processing plant. The lining is due to be replaced, but the engineering team needed to stem the leak that was costing them dearly in water top ups

APPLICATION SITUATION

It would have been almost impossible to repair this live leak using anything other than Belzona. The normal option would be to weld a patch to it, but the substrate and the internal liner meant that hot works were not possible

APPLICATION METHOD

80 grade emery was used to "key" the area. This is a tried and tested method used at many of the Waste Water sites and the same substrates throughout the UK

The area was cleaned and degreased

A mild steel patch was cut to size from 3mm sheet and was prepared using an angle grinder and cutting disc

The Belzona 1212 was mixed according to the IFU and both the target area and patch were "wetted" out

The plate had the Belzona 1212 applied to it and then was pressed against the tank wall

A wooden sprag was employed to hold the plate in place until full cure

The repair was visited 2 months later and was holding perfectly well with no signs of leakage

BELZONA FACTS

Less than 1 x 450g unit of Belzona 1212 was used in this repair, a fraction of the cost of any other method that would have provided a solution.

INDUSTRY

Food & Drink

LOCATION

Newark

APPLICATION DATE

May 2025

PRODUCTS

Belzona 1212

SUBSTRATE

Other

PHOTOS

1. The large water tank with compromised liner and through wall leak
2. Showing a small, but costly leak toward the bottom of the tank
3. Showing plate bonding to a live leak using Belzona 1212
4. Another angle of the repair

For more examples of Belzona Know-How in Action, please visit khia.belzona.com

Belzona products are manufactured under an ISO 9001 Registered Quality Management System.

www.belzona.com

